

Certificate of constancy of performance,

0832-CPR-F1735

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

MCP5A-RPwwxx-yyyy-zz Indoor Surface/Flush Mounting Addressable Call Point with Short Circuit Isolator
Advanced Protocol (and System Sensor 500 Series Protocol)
(For full product details and conditions of use refer to appendix)

Produced by or for

KAC Alarm Company Limited

KAC House
Thornhill Road
North Moons Moat
Redditch
Worcestershire
B98 9ND
United Kingdom

and produced in the manufacturing plant(s)

KAC Alarm Company Limited

KAC House
Thornhill Road
North Moons Moat
Redditch
Worcestershire
B98 9ND
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-11:2001 + A1:2005 - Manual call points
EN 54-17:2005 - Short circuit isolators

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 10 March 2017 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 10 March 2017
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1735

Variants:

MCP5A-RPwwxx-yyyy-zzC

C = Hinged cover fitted

Blank character if not applicable

Ancillaries:

SR Surface mounting plastic box

SR1T Surface mounting plastic box c/w 1 terminal

SR2T Surface mounting plastic box c/w 2 terminals

SR3T Surface mounting plastic box c/w 3 terminals

SR4T Surface mounting plastic box c/w 4 terminals

MR Surface mounting metal box

ETT European Terminal Tray ETT1, 2 & 3

L Earth Continuity Link

M141 Spacer Piece

PTR Pattress PTR, PTRE, PTR2T, PTR2TE, PTR3T & PTR3TE

C Hinged Cover

Notes:

Key to variable characters:

1. wwXx indicates mounting (S=Surface mounted, F=Flush mounted, P=Pattress mounted, 1-4=Surface mounted with 1-4 terminals)
2. xG=Glass element; xF=Flexible element
3. yyyy = Customer account code; (range: A000 to Z999 or STCK for standard stocked product)
4. zz (range: 0-99_ indicates customer marking options detailed on KAC controlled drawing 08/2639)
5. ww (range 0-99 even numbers only) indicates the communication software protocol



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 10 March 2017
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.