

Certificate of constancy of performance

0832-CPR-F0269

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

MI-WST-PC-I Analogue Addressable Wall Mounted LED Strobe with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Produced by or for

Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)

Charles Avenue
Burgess Hill
West Sussex
RH15 9UF
United Kingdom

and produced in the manufacturing plant(s)

KAC Alarm Company Ltd

Thornhill Road
North Moons Moat
Redditch
B98 9ND
United Kingdom


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-17:2005 - Short circuit isolators EN 54-23:2010 - Visual alarm devices

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 11 April 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 11 April 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0269

Bases / Ancillaries:

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C

Notes:

1. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details):
 - Category O: O-2.4-2
 - Flash rate 1Hz
 - Synchronization
2. *Type A with Bcc deep back box, Type B with Wcc deep back box*



Martin McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 11 April 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.