

Certificate of Product Approval

Certificate Number: 166s-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Javastrasse 2
CH-8604
Hegnau
Switzerland



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

WSS-xC-Ny

DSS-xC-Nyy

(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

04 August 2017

Date of Issue

04 August 2017

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 166s-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Certified Product	Description	LPCB Ref.No.
WSS-xC-Nyy	<p>Analogue Addressable Wall Mounted Sounder / LED Strobe (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): <ul style="list-style-type: none"> - Category O – Open Class - Flash rate 1Hz - Synchronization x indicates body colour. D=Detector White, P=Pure White yy indicates customer and associated communication protocol. <ul style="list-style-type: none"> 01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol) Type A with Bcc deep back box, Type B with Wcc deep back box Meets the requirements of EN54-3: 2001 at the following tones: <ol style="list-style-type: none"> 1) Alternating 525/440, 2Hz (100ms/400ms); 2) Alternating 800/922, 1Hz; 3) Alternating 800/922, 2Hz; 4) Alternating 2400/2900, 3Hz; 5) Alternating 2500/3100, 2Hz; 6) Alternating 988/645, 2Hz; 7) Continuous 630Hz; 8) Continuous 922Hz; 9) Continuous 1200Hz; 10) Continuous 2810Hz; 	166s/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

04 August 2017

Date of Issue

04 August 2017

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 166s-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Certified Product	Description	LPCB Ref.No.
	11) Sweep 150-1000Hz, rise 10s, stable 40s, fall 10s, stable 20s, then repeating; 12) Intermittent 420Hz, 0.625s on, 0.625 sec off; 13) Sweep 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) Intermittent 630, 3.33Hz, 150ms on, 150ms off; 15) Intermittent 922, 0.8Hz 0.25s on, 1s off; 16) Intermittent 922, 0.5Hz 1s on, 1s off; 17) Intermittent 2810, 1Hz; 18) Intermittent 922, 1Hz 500ms on, 500ms off; 19) Intermittent 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) Continuous 800Hz; 21) Sweep 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) Sweep 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) Sweep 2400 – 2850, 7Hz; 24) Sweep 500 – 1200Hz, (0.5s off, 3.5s on); 25) Sweep 800 – 970, 50Hz; 26) Sweep 800 – 970, 7Hz; 27) Sweep 800 – 970, 1Hz; 28) Sweep 2400 – 2850, 50Hz; 29) Sweep 500 – 1000, 7Hz; 30) Sweep 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) Sweep 800 – 1000, 2Hz; 32) Sweep 2400 – 2850, 1Hz	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

04 August 2017
Date of Issue

04 August 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 166s-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Certified Product	Description	LPCB Ref.No.
DSS-xC-Nyy	<p>Analogue Addressable Type A Integrated Detector Base Sounder/Beacon (B501AP base)</p> <p>Notes:</p> <ol style="list-style-type: none"> The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): <ul style="list-style-type: none"> - Category O – Open Class - Flash rate 1Hz - Synchronization x indicates body colour, D=Detector White, P=Pure White yy indicates customer and associated communication protocol. <ul style="list-style-type: none"> 01 indicates Advanced Protocol (and Honeywell 500 series protocol) 00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol) Meets the requirements of EN54-3 for all output levels at voltage range 15-32VDC and tones: <ol style="list-style-type: none"> 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 150-1000, rise 10s, stable 40s, fall 10s, stable 20s, then repeating; 	166s/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

04 August 2017

Date of Issue

04 August 2017

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 166s-(cl-2)

Issue: 01

Life Safety Distribution GmbH, System Sensor Europe

Certified Product	Description	LPCB Ref.No.
	12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz.	

Ancillaries / Bases

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof back box IP33C

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

04 August 2017
Date of Issue

04 August 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

