

## Certificate of Product Approval

Certificate Number: 166t-(cl-1)

Issue: 01

### Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)

Caburn House  
2B Brooks Road  
Lewes  
East Sussex  
BN7 2BY  
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Audible Warning Devices

MI-WST-PC-N

MI-VAD-WC-N

(refer to Appendix for details)

#### Standards

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

19 February 2018

Date of Issue

19 February 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 166t-(cl-1)

Issue: 01

### Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)

Certified Product	Description	LPCB Ref.No.
MI-WST-PC-N	Analogue Addressable Wall Mounted LED Strobe (B501AP base) Notes: 1. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization 2. Type A with Bcc deep back box, Type B with Wcc deep back box	166t/01
MI-VAD-WC-N	Analogue Addressable High Output Beacon (B501AP base) Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): - Category C: C-3-5.1, C-6-5.1, C-9-5.1 - Category W: W-2.4-2.76 - Flash rate 0.5Hz - Synchronization 2. Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW	166t/02

#### Ancillaries

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C
WPW	Deep back box for outdoor (White)
WRR	Deep back box for outdoor (Red)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

19 February 2018

Date of Issue

19 February 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


