

## Certificate of Product Approval

Certificate Number: 166m-(cl-1)

Issue: 02

### Morley IAS by Honeywell

Caburn House  
2B Brooks Road  
Lewes  
BN7 2BY  
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Audible Warning Devices

MI-WST-PC-I  
MI-VAD-WC-I

#### Standards

EN 54-17: 2005  
EN 54-23: 2010

(Refer to Appendix for details)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

M McCullagh

Verifier

01 February 2016

Date of Issue

11 April 2014

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 166m-(cl-1) Morley IAS by Honeywell

Issue: 02

Certified Product	Description	LPCB Ref.No.
MI-WST-PC-I	Analogue Addressable Wall Mounted LED Strobe with Short Circuit Isolator (B501AP base) Notes: 1. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization 2. Type A with Bcc deep back box, Type B with Wcc deep back box	166m/01
MI-VAD-WC-I	Analogue Addressable High Output Beacon with Short Circuit Isolator (B501AP base) Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): - Category C: C-3-5.1, C-6-5.1, C-9-5.1 - Category W: W-2.4-2.76 - Flash rate 0.5Hz - Synchronization 2. Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW	166m/02

### Ancillaries

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C
WPW	Deep back box for outdoor (White)
WRR	Deep back box for outdoor (Red)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh  
Verifier

01 February 2016  
Date of Issue

11 April 2014  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



**bre**