

Certificate of Product Approval

Certificate Number: 166m-(cl-3)

Issue: 02



Notifier by Honeywell

Caburn House
2B Brooks Road
Lewes
BN7 2BY
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Audible Warning Devices

NFXI-WF-WC
NFXI-WCF-WC

(Refer to Appendix for details)

Standards

EN 54-17: 2005
EN 54-23: 2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

M McCullagh
Verifier

01 February 2016
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 166m-(cl-3) Notifier by Honeywell

Issue: 02

Certified Product	Description	LPCB Ref.No.
NFXI-WF-WC	Analogue Addressable Wall Mounted LED Strobe with Short Circuit Isolator (B501AP base) Notes: 1. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following category (light pattern details): - Category O: O-2.4-2 - Flash rate 1Hz - Synchronization 2. Type A with Bcc deep back box, Type B with Wcc deep back box	166m/01
NFXI-WCF-WC	Analogue Addressable High Output Beacon with Short Circuit Isolator (B501AP base) Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): - Category C: C-3-5.1, C-6-5.1, C-9-5.1 - Category W: W-2.4-2.76 - Flash rate 0.5Hz - Synchronization 2. Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW	166m/02

Ancillaries

B501AP	Mounting base – Low profile base IP21C
Bcc	Deep back box
Wcc	Waterproof deep back box IP33C
WPW	Deep back box for outdoor (White)
WRR	Deep back box for outdoor (Red)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

01 February 2016
Date of Issue

11 April 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre