

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F1344

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MI-VAD-WC-I Analogue Addressable High Output Beacon with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Morley IAS by Honeywell
Caburn House
2B Brooks Road
Lewes
BN7 2BY
United Kingdom

and produced in the manufacturing plant(s):

KAC Alarm Company Ltd
Thornhill Road
North Moons Moat
Redditch
Worcestershire B98 9ND
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-17:2005 - Short circuit isolators
EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of Issue: 16 October 2019

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1344**MI-VAD-WC-I Analogue Addressable High Output Beacon with Short Circuit Isolator****Notes:**

1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details):
 - Category C: C-3-5.1, C-6-5.1, C-9-5.1
 - Category W: W-2.4-2.76
 - Flash rate 0.5Hz
 - Synchronization
2. Type A indoor use with B501AP only, Type B outdoor use with B501AP and WRR or WPW

Ancillaries:

B501AP	Mounting base – Low profile base IP21C
WPW	Deep back box for outdoor (White)
WRR	Deep back box for outdoor (Red)



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.