

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2086

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

DSS-xC-Nyy Analogue Addressable Type A Integrated Detector Base Sounder/Beacon

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Life Safety Distribution GmbH, System
Sensor Europe
Javastrasse 2
CH-8604
Hegnau
Switzerland**

**KAC Alarm Company Ltd
Thornhill Road
North Moons Moat
Redditch
Worcestershire B98 9ND
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-3:2001 + A1:2002 + A2:2006 – Sounders
EN 54-23:2010 - Visual alarm devices**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 16 October 2019

Date of Issue: 16 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2086**DSS-xC-Nyy Analogue Addressable Type A Integrated Detector Base Sounder/Beacon****Notes:**

1. The wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details):

- Category O – Open Class
- Flash rate 1Hz
- Synchronization

2. x indicates body colour. D=Detector White, P=Pure White

3. yy indicates customer and associated communication protocol.

01 indicates Advanced Protocol (and Honeywell 500 series protocol)

00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol)

4. Meets the requirements of EN54-3 for all output levels at voltage range 15-32VDC and tones:

- 1) 554/440, 2Hz (100ms/400ms);
- 2) 800/970, 1Hz;
- 3) 800/970, 2Hz;
- 4) 2400/2900, 3Hz;
- 5) 2500/3100, 2Hz;
- 6) 988/645, 2Hz;
- 7) 660Hz;
- 8) 970Hz;
- 9) 1200Hz;
- 10) 2850Hz;
- 11) 150-1000, rise 10s, stable 40s, fall 10s, stable 20s, then repeating;
- 12) 420Hz, 0.625s on, 0.625 sec off;
- 13) 500-1200Hz, 0.25 sec off, 3.75 sec on;
- 14) 660, 3.33Hz, 150ms on, 150ms off;
- 15) 970, 0.8Hz 0.25s on, 1s off;
- 16) 970, 0.5Hz 1s on, 1s off;
- 17) 2850, 1Hz;



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2086

- 18) 970, 1Hz 500ms on, 500ms off;
- 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off;
- 20) 800Hz;
- 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off;
- 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off;
- 23) 2400 – 2850, 7Hz;
- 24) 500 – 1200Hz, (0.5s off, 3.5s on);
- 25) 800 – 970, 50Hz;
- 26) 800 – 970, 7Hz;
- 27) 800 – 970, 1Hz;
- 28) 2400 – 2850, 50Hz;
- 29) 500 – 1000, 7Hz;
- 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s;
- 31) 800 – 1000, 2Hz;
- 32) 2400 – 2850, 1Hz.

Base:

B501AP Mounting base – Low profile base IP21C



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.