

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2256

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MI-BSS-xx-I Analogue Addressable Type A Integrated Base Sounder/Strobe with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Morley-IAS Fire Systems by Honeywell
(Pittway Systems Technology Group
(Europe) Ltd)
Caburn House
2B Brooks Road
Lewes, East Sussex
BN7 2BY
United Kingdom

KAC Alarm Company Limited
Thornhill Road
North Moons Moat
Redditch
Worcestershire B98 9ND
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 – Sounders EN 54-17:2005 - Short circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of Issue: 16 October 2019

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2256**MI-BSS-xx-I Analogue Addressable Type A Integrated Base Sounder/Strobe with Short Circuit Isolator****Bases / Ancillaries:**

B501AP-cc Low profile base IP21C, cc indicates colour, Blank=Pure White, IV=Detector White
Bcc Deep base IP44, cc indicates colour, RR=Red, DD=Detector White, PW=Pure White
Wcc Waterproof base IP65, cc indicates colour, RR=Red, DD=Detector White, PW=Pure White

Notes:

1. xx indicates body/lens colour. PR=Pure White/Red, PA=Pure White/Amber, PC=Pure White/Clear, DR=Detector White/Red, DA=Detector White/Amber, DC=Detector White/Clear
2. yy indicates customer and associated communication protocol.
01 indicates Advanced Protocol (and Honeywell 500 series protocol)
00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol)
3. Meets the requirements of EN54-3 for all output levels at voltage range 15-29VDC and tones:
 - 1) 554/440, 2Hz (100ms/400ms);
 - 2) 800/970, 1Hz;
 - 3) 800/970, 2Hz;
 - 4) 2400/2900, 3Hz;
 - 5) 2500/3100, 2Hz;
 - 6) 988/645, 2Hz;
 - 7) 660Hz;
 - 8) 970Hz;
 - 9) 1200Hz;
 - 10) 2850Hz;
 - 11) 150-1000, rise 10s, stable 40s, fall 10s, stable 20s, then repeating;
 - 12) 420Hz, 0.625s on, 0.625 sec off;
 - 13) 500-1200Hz, 0.25 sec off, 3.75 sec on;
 - 14) 660, 3.33Hz, 150ms on, 150ms off;
 - 15) 970, 0.8Hz 0.25s on, 1s off;
 - 16) 970, 0.5Hz 1s on, 1s off;
 - 17) 2850, 1Hz;
 - 18) 970, 1Hz 500ms on, 500ms off;
 - 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off;
 - 20) 800Hz;
 - 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off;
 - 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off;



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2256

- 23) 2400 – 2850, 7Hz;
 - 24) 500 – 1200Hz, (0.5s off, 3.5s on);
 - 25) 800 – 970, 50Hz;
 - 26) 800 – 970, 7Hz;
 - 27) 800 – 970, 1Hz;
 - 28) 2400 – 2850, 50Hz;
 - 29) 500 – 1000, 7Hz;
 - 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s;
 - 31) 800 – 1000, 2Hz;
 - 32) 2400 – 2850, 1Hz.
4. Certification excludes the strobe function.



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.